

WATER SERVICE CONNECTION INFORMATION

- Water service pipe to be 36" deep.
- Backfill with clean dirt or screening cover 6" depth, minimum.
- Install a pvc sleeve through foundation wall and seal watertight.
- Inside house:
 - A full port ball valve
 - A $\frac{3}{4}$ " minimum pressure reducer
 - Meter
 - A dual check valve (700 watts or equivalent)
 - A full-port ball valve
 - An expansion tank is required. If existing water heater has one, an additional expansion tank is not required.
- Test when completed.